

CERTIFICATE OF CONFORMITY – PORTABLE FIRE EXTINGUISHERS

Certificate of conformity reference number: **KB 10/16**

Test specification: **EN 3-7 : 2004 + A1 : 2007**

Test report no.: **20150569-1**

Requested by: **BONPET SYSTEMS d.o.o., Obrtniška cesta 30, 1420 TRBOVLJE, SLOVENIA**

Manufacturer: **BONPET SYSTEMS d.o.o., Obrtniška cesta 30, 1420 TRBOVLJE, SLOVENIA**

Model name: **BFE2** Trade mark: **Bonpet systems**

Assembly drawing no.: **2015-0101** List of parts no.: **2015-0101**

Fire extinguishing medium: **Bonpet fire-extinguishing liquid** Operation device: **Grip lever**
Reference no. KB 185/14

Propellant: **15 bar / 20°C nitrogen in cylinder** Special detail: **Nozzle according to drawing no. KX09-003-28D1**

Test fire rating: **8 A, 55 B and 25 F according to EN 3-7** Range of operating temperature: **0 °C to 60 °C**

Notes: **–**

Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for fire extinguishers which correspond to the submitted test samples and to the confirmed documents.

This certificate of conformity does not include surveillance.

11th January, 2016



Grad. Eng. Jürgen Dittrich
Laboratory Manager



MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268
Steuernummer: 220/114/03364
USt-IdNr. DE291271296

Sparkasse Mittelsachsen
Poststraße 1a
09599 Freiberg
IBAN DE68 870520003115024672
BIC WELADED1FGX

CERTIFICATE OF CONFORMITY – PORTABLE FIRE EXTINGUISHERS

Certificate of conformity reference number: **KB 11/16**

Test specification: **EN 3-7 : 2004 + A1 : 2007**

Test report no.: **20150569-2**

Requested by: **BONPET SYSTEMS d.o.o., Obrtniška cesta 30, 1420 TRBOVLJE, SLOVENIA**

Manufacturer: **BONPET SYSTEMS d.o.o., Obrtniška cesta 30, 1420 TRBOVLJE, SLOVENIA**

Model name: **BFE6** Trade mark: **Bonpet systems**

Assembly drawing no.: **2015-0201** List of parts no.: **2015-0201**

Fire extinguishing medium: **Bonpet fire-extinguishing liquid** Operation device: **Grip lever**
Reference no. KB 185/14

Propellant: **15 bar / 20°C nitrogen in cylinder** Special detail: **Horn according to drawing no. JA-F6-02**

Test fire rating: **27 A, 144 B and 75 F according to EN 3-7** Range of operating temperature: **0 °C to 60 °C**


Notes: **—**

Conformity to the above mentioned test specification is attested. All applicable requirements have been met.

This certificate of conformity is valid solely for fire extinguishers which correspond to the submitted test samples and to the confirmed documents.

This certificate of conformity does not include surveillance.

11th January, 2016



Grad. Eng. Jürgen Dittrich
Laboratory Manager



MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268
Steuernummer: 220/114/03364
USt-IdNr. DE291271296

Sparkasse Mittelsachsen
Poststraße 1a
09599 Freiberg
IBAN DE68 870520003115024672
BIC WELADED1FGX